

MIDWESTERN STATE UNIVERSITY

09 51 13

ACOUSTICAL PANEL CEILING

PART 1: GENERAL

1.01 Scope of Standard

- A. This standard provides general guidance concerning the specific preferences of Midwestern State University for acoustical ceiling tiles and panels.
- B. Midwestern State University recognizes that project conditions and requirements vary, thus precluding the absolute adherence to the items identified herein in all cases. However, unless there is adequate written justification, it is expected that these guidelines will govern the design and specifications for Midwestern State University projects.

1.02 Design Guidelines

- A. Patterns: Patterns shall be fissured and non-directional.
- B. Color: White, unless otherwise approved by Midwestern State University project representative.
- C. Edge conditions: Panels shall be no less than 6” where adjacent to walls. Edge trim shall be “L” type.
- D. Fire resistant assemblies: Acoustical ceilings are not to be used.
- E. Asbestos: In no instance will any product containing asbestos be acceptable for use.

1.03 General Requirements

- A. Over-stock: Provide 5% overage for attic stock.

SECTION 09 51 13 – ACOUSTICAL PANEL CEILING
CONSTRUCTION STANDARDS

PART 2: PRODUCTS

2.01 Ceiling Panel

A. Panel

1. Panel: 24" x 24" x 5/8" lay-in acoustical ceiling tile Cortega No. 770, as manufactured by Armstrong or equal.
2. Building or Room Renovations: Use acoustical tiles, which match existing panels in space. Use Armstrong 24" x 24" x 5/8" Cortega 770 in isolated renovations.

PART 3: EXECUTION (NOT USED)

END OF SECTION 09 51 13