



Office of Purchasing/Contract Management
3410 Taft Boulevard Wichita Falls, Texas 76308-2099

ADDENDUM FOUR (4)

August 8, 2017

TO WHOM IT MAY CONCERN

Reference: RFP #735-17-8184 Fantasy of Lights Warehouse Expansion

Clarification of Building Layout and Gutters

- In replacing the existing 100 amp service to 200 amp, this will include the meter, riser, & main panel with a 200 amp main breaker.

If you have any questions do not hesitate to contact me.

Thank You.

Sincerely,

Steve Shelley

Director of Purchasing & Contract Management

940-397-4110

stephen.shelley@mwsu.edu