



Office of Purchasing/Contract Management
3410 Taft Boulevard Wichita Falls, Texas 76308-2099

09/28/18

ADDENDUM THREE (3)

RE: RFP 735-18-4285 Moffett Library Reading Room Asbestos Abatement

TO WHOM IT MAY CONCERN:

The following questions had been received after the posting of ADDENDUM 1:

- Since the plaster above the upper side arch was added in Addendum #1, do you have a ballpark guess of the quantity of the plaster that needs to be removed? Total amount of plaster.
Approximately 240 SF
- The asbestos specs state that *"the associated overspray quantity is unknown"*. I see on the Second Floor drawing that the 3-layer critical barrier work zone on the Second Floor is a little larger than the first floor. If, during abatement in that area, we see overspray **beyond** the red-dotted line, do you want us to continue abating beyond that? Basically, since quantities are unknown, we are trying to calculate how far to go to remove overspray. **As stated at walkthrough there is no visible overspray outside of the work area. Addendum 1 has a second floor area DRAWING. The new barrier is drawn right around the work area.**

At this point, no additional questions will be accepted.

Regards,

Joseph J. Mrugalski Jr.
Purchasing/Contract Management
Midwestern State University