



Office of Purchasing/Contract Management
3410 Taft Boulevard Wichita Falls, Texas 76308-2099

10/23/18

ADDENDUM ONE (1)

RE: RFP 735-19-4290 Fain Fine Arts Motor Starter Replacement Project

TO WHOM IT MAY CONCERN:

- The PRE-BID MEETING scheduled for October 29, 2018 @ 10 am is **MANDATORY**. Vendors submitting bids must attend. The Pre-Bid Meeting will be located at the west main entrance of Fain Fine Arts.
- Please **disregard** the list of motor starters listed in Section 5 of the SOW in the RFP. The following updated list of motor starter specifications replaces the list in Section 5 of the SOW in the RFP

Air Handler # B-4 SA on Nth end, up thru East Wagonhouse B121	
Motor specs	Westing House 1775 RPM, 60 HP, 480 Volts, 3 Phase, 364-T Frame
Air Handler # B-4 RA on Sth end, up thru East Wagonhouse B121	
Motor specs	U S Electric 1750 RPM, 20 HP, 460 Volts, 3 Phase, 256-T Frame
Air Handler # C-1 RA on Nth end, up thru East Wagonhouse B121	
Motor specs	Westing House, 1760 RPM, 15 HP, 460 Volts, 3 Phase, 254-T Frame
Air Handler # D1, Roof D202, thur Mech Rm B220, up thru East Wagonhouse B121	
Motor specs	Westing House, 1760 RPM, 50 HP, 460 Volts, 3 Phase, 326-T Frame
Return Air Handler # D1, Roof D202, thur Mech Rm B220, up thru East Wagonhouse B121	
Motor specs	Dayton, 1770 RPM, 15 HP, 460 Volts, 3 Phase 254-T Frame

- Please use the attached bid sheet when submitting pricing information.

Regards,
Joseph J. Mrugalski Jr.
Purchasing/Contract Management
Midwestern State University