



Office of Purchasing/Contract Management
3410 Taft Boulevard Wichita Falls, Texas 76308-2099

04/03/2020

ADDENDUM ONE (1)

RE: RFP# 735-20-8222 MSU 2733 Midwestern Parkway Concrete Work (Response to Questions)

TO WHOM IT MAY CONCERN:

The following questions had been received prior to the last day for questions deadline and received the following responses in blue:

- CD101, note 12 for Alternate 6 states the length of the concrete being demoed is ~225 LF. The width shall be from the edge of the asphalt on both sides of this curb peninsula (~75”), NOT curb to curb (~42”). Area between red lines in the attached photo is to be completely demoed, although light pole piers are to remain.

Thank you,

Tracy Nichols
Purchasing/Contract Management
Midwestern State University