



Office of Purchasing/Contract Management  
3410 Taft Boulevard Wichita Falls, Texas 76308-2099

January 18, 2022

**ADDENDUM TWO (2)**

RE: RFP 735-22-4360 HVAC System Modifications @ Museum

TO WHOM IT MAY CONCERN,

The following question was submitted and received the following response.

- In reference to detail number 2 on plan sheet M2.1, we do not see how it is possible to build these bulkhead enclosures as they are drawn. The problem we see is the inside portion with the 1" Johns Manville Permacoat Linacoustic Rigid insulation. We do not see how to fasten this board to the inside of the enclosures. Is there as alternate method of building these enclosures that would be acceptable? [The interior liner can be attached using 2" diameter metal disks or washers with wire extending through the insulation \(and sheetrock if needed\) to hold the insulation in place. There is very little pull on the insulation and if rigid insulation is used then holding the insulation in place is fairly simple.](#)

Due to the issuance of Addendum 2, the Deadline for Submission of Offers has been updated to allow respondents time to adjust their responses. The new Deadline for Submission of Offers is as follows:

- Deadline for Submission of Offers: January 25, 2022 (2:00 pm CT)

The deadline for additional questions has passed. **No additional questions will be accepted at this time.**

Please remember to acknowledge this addendum on the Addenda Checklist.

Regards,

Joseph J. Mrugalski Jr.  
Purchasing/Contract Management