



Office of Purchasing/Contract Management
3410 Taft Boulevard Wichita Falls, Texas 76308-2099

06/20/2019

ADDENDUM TWO (2)

RE: RFP #735-19-8218 New Museum Monument Sign

TO WHOM IT MAY CONCERN:

The following questions had been received prior to the last day for questions deadline and received the following responses (Questions are in **black**/responses are in **red**):

- I was asked yesterday by a contractor to provide pricing for the lettering on the sign. I don't see anything on the drawing they brought in regarding the thickness of the letters, the material, the Font style, or the finish on the letters. I also didn't see anything on the website with this info. All of these things make a difference in the price of the letters.

The following is from a submittal for the Vinson Health Center sign on Redwine which should be used for this project:

Supplier: A.R.K. Ramos Signage Systems, Oklahoma City.

Material: Cast Aluminum.

Font: Heavy Ribbon.

Finish: F-6D, Dark Bronze, 313 Anodized.

Mounting: PM-1, 1" Projected Mounting.

Per the chart on page 7 of <https://arkramos.com/wp-content/uploads/2019/03/ARK-RAMOS-CATALOG-UPDATED-1.pdf>, the depth and stroke (i.e., depth, I think) of the letters varies with their height. Height requirements are defined on the museum sign drawing.

Thank you,
Tracy Nichols
Purchasing/Contract Management
Midwestern State University